

---

---

**INTEROFFICE MEMORANDUM**

---

---

**TO:** PLANNING DEPARTMENT  
**FROM:** ROBERT C. CRAIG, FIRE DEPARTMENT  
**SUBJECT:** APPLICATION FOR PCRC SPECIAL PERMIT AT 12 SUMMER STREET (REAR)  
**DATE:** 4/11/2012

---

Please be advised that I have reviewed the above-named application and related materials. I would concur with the observations of the Planning Director and the Engineering Department. More specifically I would comment on the following items which are of concern:

- 1) Long driveway with inadequate or no turn-around.
- 2) No water supply, hydrants for fire protection indicated.
- 3) Questionable drive construction and width.
- 4) Questionable driveway interface with cemetery driveway.
- 5) Not able to determine the ability of fire apparatus to turn into proposed project without crossing center-line of traffic on Central Street.
- 6) No fire alarm call box indicated so there may be an excessive travel distance to a fire alarm call box.